



A



EN54-4 PSU ENCLOSURE  
 SIZE: 13.8" X 11.4" X 7.4" (350mm X 288.6mm X 188.2mm)  
 MANUFACTURER: SLAT POWER SUPPLIES  
 MANUF. PART NUMBER: AES 24V C38

B

C



EXTERNAL CONNECTIONS:  
 ETHERNET  
 EWS-4 PSU FAULT

LOCKABLE DOOR  
 CABINET MUST BE EARTHED (GROUNDED)

D

E

EWS-4 CABINET  
 SIZE: 20" X 16" X 6" (508mm X 406mm X 152mm)  
 MANUFACTURER: HAMMOND MFG  
 MANUF. PART NUMBER: EN4SD20166WGY  
 INTERNAL PANEL PART NUMBER: EP2016

EN54-16 EWS-4 CABINET WITH EN54-4 PSU  
 CABINET MEETS IP30 STANDARDS

F

THE INFORMATION DISCLOSED HEREIN WAS ORIGINATED BY AND IS THE PROPERTY OF BIAMP SYSTEMS AND EXCEPT FOR THE RIGHTS EXPRESSLY GRANTED TO THE UNITED STATES GOVERNMENT, BIAMP SYSTEMS RESERVES ALL PATENT, PROPRIETARY, DESIGN USE, SALE, MANUFACTURING AND REPRODUCTION RIGHTS THERETO.


REFERENCE: EN54-16 WS CABINET ASSEMBLY  
 MATERIAL: NA  
 FINISH: NA  
 WEIGHT: (grams) NA  
 UNLESS OTHERWISE SPECIFIED:  
 DIMENSIONS ARE IN MILLIMETRES  
 THIRD ANGLE PROJECTION



Biamp Systems Pty Ltd  
 Unit 2, 87 Webster Road  
 Stafford, Queensland, 4053  
 AUSTRALIA  
 Phone: (+61)(0)7 3552 9552  
 Fax: (+61)(0)7 3352 5578

ISSUE	DESCRIPTION	REVISION	AMEND	DATE
1	INITIAL	A	WEN	28.01.10
2	ADD PSU ENCLOSURE	A	WEN	19.02.10
3				
4				

TITLE:		Vocia EN54-16 INSTALLATION EWS-4 CABINET	
DWG NO.		A4.4636	
CHECKED:	WEN	APPROVED:	WJD
SHEET 1 OF 3		DO NOT SCALE DRAWING	



THE INFORMATION DISCLOSED HEREIN WAS ORIGINATED BY AND IS THE PROPERTY OF BIAMP SYSTEMS AND EXCEPT FOR THE RIGHTS EXPRESSLY GRANTED TO THE UNITED STATES GOVERNMENT, BIAMP SYSTEMS RESERVES ALL PATENT, PROPRIETARY, DESIGN USE, SALE, MANUFACTURING AND REPRODUCTION RIGHTS THERETO.

REFERENCE: EN54-16 WS CABINET ASSEMBLY  
 MATERIAL: NA  
 FINISH: NA  
 WEIGHT: (grams) NA  
 UNLESS OTHERWISE SPECIFIED:  
 DIMENSIONS ARE IN MILLIMETRES  
 THIRD ANGLE PROJECTION

**biamp.**

Biamp Systems Pty Ltd  
 Unit 2, 87 Webster Road  
 Stafford, Queensland, 4053  
 AUSTRALIA  
 Phone: (+61)(0)7 3552 9552  
 Fax: (+61)(0)7 3352 5578

ISSUE	DESCRIPTION	REVISION	AMEND	DATE
1	INITIAL	A	WEN	19.02.10
2				
3				
4				

TITLE:		Vocia EN54-16 INSTALLATION EWS-4 CABINET REAR	
DWG NO.		A4.4636	
CHECKED:	WEN	APPROVED:	WJD
SHEET 2 OF 3		DO NOT SCALE DRAWING	

1

2

3

4

A


B

C

D

E

F



EN54-4 PSU ENCLOSURE

(CUT AWAY VIEW TO SHOW MOUNTING FASTENERS)

4x Ø6mm PAN HEAD SCREWS

4x Ø6.5mm MOUNTING HARDWARE HOLES

MOUNTING SPACERS:


USE > Ø6mm WASHERS TO ACHIEVE A HEIGHT GREATER THAN OR EQUAL TO 4mm

Ø16mm CABLE ACCESS HOLE

Ø16mm CABLE ACCESS HOLE

4x Ø6.5mm MOUNTING HARDWARE HOLES

4x Ø6mm HEX NUTS



EN54-16 EWS-4 CABINET

EN54-16 ENCLOSURE + PSU ENCLOSURE = EN54-16 CABINET

THE INFORMATION DISCLOSED HEREIN WAS ORIGINATED BY AND IS THE PROPERTY OF BIAMP SYSTEMS AND EXCEPT FOR THE RIGHTS EXPRESSLY GRANTED TO THE UNITED STATES GOVERNMENT, BIAMP SYSTEMS RESERVES ALL PATENT, PROPRIETARY, DESIGN USE, SALE, MANUFACTURING AND REPRODUCTION RIGHTS THERETO.

REFERENCE: EN54-16 WS CABINET ASSEMBLY  
 MATERIAL: NA  
 FINISH: NA  
 WEIGHT: (grams) NA  
 UNLESS OTHERWISE SPECIFIED:  
 DIMENSIONS ARE IN MILLIMETRES  
 THIRD ANGLE PROJECTION

**biamp.**

Biamp Systems Pty Ltd  
 Unit 2, 87 Webster Road  
 Stafford, Queensland, 4053  
 AUSTRALIA  
 Phone: (+61)(0)7 3552 9552  
 Fax: (+61)(0)7 3352 5578

ISSUE	DESCRIPTION	REVISION	AMEND	DATE
1	INITIAL	A	WEN	19.02.10
2				
3				
4				

TITLE: Vocia  
 EN54-16 INSTALLATION  
 EWS-4 CABINET MOUNTING HARDWARE

DWG NO. A4.4636

CHECKED: WEN APPROVED: WJD SHEET 3 OF 3 DO NOT SCALE DRAWING